Three phase in telligent reclosing protector



Overview:

The DTS6619 three-phase four wire overvoltage and undervoltage current limiting protector is currently available in the market

A new generation of home appliance protection device developed by the Electric Condition Institute. Control circuit selection

Assembled with imported components, produced using modular standards for performance Excellent and reliable. Capable of being positive under

abnormal voltage, current, and phase sequence conditions Work regularly. When the mains voltage and current exceed the action threshold of the protector

When the phase sequence is disordered and the voltage and current are unbalanced, the protector can quickly Reliably cut off the circuit to protect electrical equipment and personal safety.

When the mains voltage returns to normal, the protector can automatically connect to the power supply

Restore power supply, automatic implementation of local functions, no need for personnel operation.

Main functions:

Overvoltage protection, undervoltage protection, overload protection, undercurrent protection, delay protection

Time protection, voltage imbalance protection, current imbalance protection, shortage

Phase protection and phase sequence protection, each parameter can be set with action threshold and on/off.

parameter can be set with action threshold and on/off.

2. The backlight display shows no action for 180 seconds,

and the relay is disconnected with a red backlight, Normal white backlight Press the up and down buttons to switch and display the voltage, current, and power of the three phases Power factor, frequency.



Real time current Real time voltage

P P	
on F	11
1000	u 50
1000	11 5 %
1.000	Lu 5 U.
1.000	I 3 5 €.

eal time voltage	Real time power

Real time power factor Real time frequency

Fault records

Record overvoltage, undervoltage, overload, low current protection, voltage imbalance, Current imbalance and phase sequence protection. Note: Graffiti App Record

WIFI indicator status:

- 1 flash indicates waiting for WIFI signal to be detected 2 slow flashes indicate WIFI offline status
- 3 long lights indicate that WIFI is connected.

Function settings:

Long pressand hold the setting button to enter the setting status display setting page, flashing the set data bits



Set the content of this bit through the up and down buttons



Short press the setting key to switch the setting bit



Short press OK to confirm the settings on this page and jump to the next settings page



Long press OK to exit the setting state and save the settings

Display the "Voltage" interface: Long press and hold to configure WIFI, and switch the display to EPS (Combined active power), long press and hold to clear the power, and display the "Frequency Interface" Restore factory configuration.

Press the up and down buttons to switch and display the voltage, current, and power of the three phases
 Power factor, frequency.




phase voltage three-phase current Three phase active power

1 11 0.955 *** 12 0.958 13 00.958	P P M F L1 0.5 0 0 COSp L2 ov 0.5 0 1
--	---------------------------------------

Three phase reactive power

Three phase power factor Three phase frequency



Active A-phase electric quantity

Active phase B electric quantity

Active C-phase electric quantity



Combined reactive Reactive forward charge Reactive reverse energy power consumption



Reactive phase A Reactive phase B Reactive C-phase electric quantity electric quantity electric quantity

Fault record:

Record overvoltage, undervoltage, overload, low current protection, voltage imbalance, Current imbalance and phase sequence protection. Note: Graffiti App Record

WIFI indicator status:

- 1 flash indicates waiting for WIFI signal to be detected
- 2 slow flashes indicate WIFI offline status
- 3 long lights indicate that WIFI is connected.


Installation and usage conditions:

- 1 Temperature: -20°C 60°C
- 2. Humidity: ≤85%
- 3. Altitude: not exceeding 2000m 4 Pollution level: Level 3
- 5.Modular design for exterior design and guide rail
- installation 6. Wiring capacity: Insulated copper wire of 35 square millimeters and below

Precautions:

- 1. This product has no isolation function. Please disconnect the front stage when repairing the circuit Circuit breaker switch
- 2. The zero line (N line) of this product is directly connected without disconnection function
- 3. The protector must be wired according to the markings
- and must not be connected incorrectly. 4. Although this product has limited current protection
- function, it cannot replace circuit breakers. Please install circuit breakers such as D747 and C65 at the front end of the line
- Short circuit protection. Damaged product.
- 5. Before use, please tighten the clamp screw to prevent poor contact and

Installation wiring and dimensions:



Guarantee period:

Within 12 months from the date of production, if there are any product quality issues, and

The strip is intact, and our factory will provide free replacement. Within 36 months, there are products available

If there is a quality issue and the seal is intact, our factory will provide free repair.

function	Set parameter range Factory default settings	Function Description	
Protection delay	(hand movement) 5second 0000-9999second(s)	Power on delay protection for sudden power outage instantaneous overvoltage or excessive surge in electrical protection.	
Upper voltage limit	60V-300V 275V	The maximum voltage limit is set to 300V. For example: set to 300V. The above voltage, after saving the data, is also 300V. (Can be set in separate phases)	
Lower voltage limit	60-300V 175V	The minimum voltage limit is set to 60%, such as setting 60% to Lower the voltage, and after saving the data, it is also 60%. (Can be set in separate phases)	
Under voltage and over voltage Protection delay	(hand movement) 20second 0000-9999secondsecond(s)	Voltage above or below the set value, protection The device automatically switches off when the voltage returns to normal Close after setting the delay time.	
Lower current limit	0.0-60A 0.0 A	For example, set the lower current in the form of 10 An and the working power if the current is lower than 10A, the day of 10 C C C C C C C C C C C C C C C C C C	
Represented	Represented as: manual recovery 0000 Represented as: immediate recovery		

function	Set parameter range	Factory default settings	Function Description
Current overload Lower limit delay	0000-9999second(s)	5second	For example, if the lower limit of the current is set, the overload delay will be 5 seconds, and if the working current is lower than the set value, the delay will be 5 seconds to pull the switch.
Current overload Lower limit delay	0000-9999second(s)	20second	For example, set the current lower limit protection to delay for 20 seconds, and after the working current is normal, close it after delaying for 20 seconds at the set value.
Upper limit of current	0.1-80A	80A	For example, if the upper limit of the current is set to 80A, if the working is to 20 £ £ £ £ £ £ £ £ £ £ £ £ £ £ £ £ £ £
Current overload Upper limit delay	0000-9999second(s)	5second	For example, if the upper limit of the current is set, the overload will delay for 5 seconds, and if the working current is higher than the set value, it will delay for 5 seconds to pull the switch.
Upper limit of current Protection delay	0000-9999second(s)	60second	To example, set the current limit protection to delay for 60 seconds, and after the working current so normal, close it after a delay of 60 seconds at the set value.

function	Set parameter range	Factory default settings	Function Description
Uneven voltage Balance protection%	On/off 0000-9999%	On	The highest and lowest values of ABC phase voltage exceed Set the% value to immediately switch off.
Current unevenness Balance protection%	On/off 0000-9999%	On	The highest and lowest values of ABC phase current exceed Set the% value to immediately switch off.
phase-sequence protection	On/off	On	If there is any phase error in the ABC phase sequence, immediately switch off.